

Lavazol™ 2 is a high pH (alkaline) liquid cleaner formulated to remove silt, colloids, organics, particulate, biological, and other acid insoluble foulants. Combining specially chosen chelants, surfactants, solubilizing and dispersing agents, Lavazol™ 2 provides excellent broad spectrum foulant removal. Ideal for periodic maintenance cleans, well water, and other light loading applications.

Features / Benefits

- Concentrated cleaner for most efficient shipping and handling
- Phosphate-free formula to reduce negative impact on the environment
- Buffered pH to maintain optimum cleaning performance throughout cleaning cycle
- Optimal results when used in conjunction with either Lavazol™ 1 or OptiClean™ A
- Classified for use in membrane systems producing drinking water (ANSI/NSF Standard 60)

Uses

- For use on reverse osmosis (RO), nanofiltration (NF), ultrafiltration (UF) and micro-filtration (MF) membranes
- Formulated to dissolve organic foulants from the membrane surface
- Effective in removing biological slime and bacterial byproduct

Specifications

Appearance	Amber or clear liquid
pH (2% solution)	10.20 - 11.20
Density (kg/liter)	1.00 - 1.10



Packaging

Pail: 5 gallon/18.9 liter

Tote: 275 gallon/1,040 liter

Drum: 55 gallon/208 liter

For special packaging options, please contact PWT or your local distributor.

Lavazol™ 2
LIQUID MEMBRANE CLEANER

Lavasol™ LIQUID MEMBRANE CLEANER 2

General Mixing & Application Instructions for Lavasol™ 2

1. Inspect all cleaning system components to include CIP tank, hoses, and cartridge filters. Flush or replace if necessary. Fill cleaning tank with RO permeate or DI water. Turn on agitator or tank recirculation pump.
2. Slowly add Lavasol™ to cleaning tank (1 gal [3.8 L] of Lavasol™ for every 50 gal [189 L] of water). Mix thoroughly. The solution pH should match product specification. If necessary, adjust pH with a membrane-approved chemical such as caustic, citric, sulfuric or hydrochloric acid. The solution should be heated up to 45°C to improve cleaning efficacy.
3. Circulate solution in the same direction as the feed flow. Typical circulation times are 30-90 minutes.* PWT recommends cleaning each stage of the system separately. Maximum flow rate per pressure vessel is 40 gpm (152 Lpm) for 8-inch elements and 10 gpm (38 Lpm) for 4-inch elements. Maximum pressure for cleaning is 60 psig (4.2 kg/cm²).
4. In cases of heavy fouling, divert the first 10-20% of cleaning solution to drain to prevent redeposition of removed solids.
5. Rinse with RO permeate before returning system to service. When returning unit to service, divert product water to drain until any residual cleaning solution has been rinsed from system.

*Depending on the nature of the fouling, a soak period may be necessary for optimum results. Please contact PWT or your local distributor for custom cleaning procedure, or consult PWT's Technical Bulletin 503 for further cleaning recommendations.

ProDose XPRT™ – Scaling Prediction Software

ProDose XPRT™ uses the most accurate scaling prediction calculations available to accurately determine effective antiscalant dosage, and cleaning chemical usage. The user can enter multiple cases to study various operating conditions, directly enter concentrate analysis, and select the best PWT product and dosage for the application.

ProDose XPRT™ is available upon request only. Please contact your PWT representative for more information.

The screenshot displays the PWT ProDose XPRT software interface. At the top, there's a header with the PWT logo and a navigation bar with tabs for UNITS (US), TEMPERATURE (Fahrenheit), PERMEATE FLOW (81.00), RECOVERY (75.0%), ANTISCALANT (SpectraGuard Liquid), DOSAGE (2.95 PPM), SOURCE (Well Water), PROJECT NAME (Project 1), and CASE (1). The main area is divided into several sections: PROJECT INFORMATION (CLIENT NAME: City of San Diego, PROJECT NAME: Project 1, LOCATION, PREPARED BY, DATE: 5/1/2016, WATER TYPE: Well Water), MEASUREMENTS (PRESET UNITS: CGS, Metric, U.S.; TEMPERATURE: Deg F; FLOW RATES: Gal/min; MASS UNITS: lb), COMMENTS (OPTIONAL), and TOTAL CASES (1 AVAILABLE). The table for TOTAL CASES has columns for Cases and Modified Date, with one entry: Case 1, Modified Date 5/27/2016. A sidebar on the left contains icons for PROJECT INFORMATION, WATER QUALITY, SYSTEM INFORMATION, CHEMICAL SELECTION, CALCULATIONS, and REPORT.



PWT Headquarters & Manufacturing
1048 La Mirada Court, Vista, California 92081

Toll-Free: 800.914.9072 | Direct: 760.639.4400 | Fax: 760.639.4439
Email: sales@pwtchemicals.com | www.pwtchemicals.com



Headquarters: 54/18 Bui Quang La, Ward 12, Go Vap District, HCMC, Viet Nam
Office: 12 DHT10B, Dong Hung Thuan Ward, District 12, HCMC, Viet Nam
Phone: (028) 6258 5368 - (028) 6291 9568
Email: info@atswatertechnology.com
Website: www.atswatertechnology.com