



Lavasol<sup>™</sup> 9 is an aggressive high pH (alkaline) liquid cleaner formulated to remove silt, clay, particulate, biological, organic and other acid insoluble foulants. Combining highly effective chelants, solubilizing and dispersing agents Lavasol<sup>™</sup> 9 provides highly effective cleaning of heavily fouled membranes. Lavasol<sup>™</sup> 9 is ideal for feed waters such as surface, well and municipal water.

# Features / Benefits

- Concentrated liquid cleaner provides efficient shipping and handling
- Buffered pHto maintain optimum cleaning performance throughout cleaning cycle
- Best results when used in conjunction with either Lavasol 1 or Lavasol 6.
- Classified for use in membrane systems producing drinking water (ANSI/NSF Standard 60)

# Uses

- For use on reverse osmosis (RO), nanofiltration (NF), ultrafiltration (UF) and micro-filtration (MF) membranes
- Formulated to dissolve organic foulants from the membrane surface
- To aid in the removal of particulate, colloidal, microbiological and other acid insoluble foulants

### **Specifications**

Appearance	Pale yellow liquid	
pH (2% solution)	12.00 -13.00	
Density (kg/L)	1.00 -1.20	Certified to NSF/ANSI 60



# Packaging

Pail: 5 gallon/18.9 liter Drum: 55 gallon/208 liter Tote: 275 gallon/1,040 liter

For special packaging options, please contact PWT or your local distributor.



### General Mixing & Application Instructions for Lavasol™9

- 1. Inspect all cleaning system components to include CIP tank, hoses, and cartridge filters. Flush or replace if necessary. Fill cleaning tank with RO permeate or DI water. Turn on agitator or tank recirculation pump.
- 2. Slowly add Lavasol<sup>™</sup> 9 to cleaning tank (1 gal [3.8 L] of Lavasol<sup>™</sup> for every 50 gal [189 L] of water). Mix thoroughly. The solution pH should match product specification. If necessary, adjust pH with a membrane–approved chemical such as caustic, citric, sulfuric or hydrochloric acid. The solution should be heated up to 45°C to improve cleaning efficacy.
- 3. Circulate solution in the same direction as the feed flow. Typical circulation times are 30-90 minutes.\* PWT recommends cleaning each stage of the system separately. Maximum flow rate per pressure vessel is 40 gpm (152 Lpm) for 8-inch elements and 10 gpm (38 Lpm) for 4-inch elements. Maximum pressure for cleaning is 60 psig (4.2 kg/cm<sup>2</sup>).
- In cases of heavy fouling, divert the first 10-20% of cleaning solution to drain to prevent redeposition of removed solids.
- 5. Rinse with RO permeate before returning system to service. When returning unit to service, divert product water to drain until any residual cleaning solution has been rinsed from system.
- \*Depending on the nature of the fouling, a soak period may be necessary for optimum results. Please contact PWT or your local distributor for custom cleaning procedure, or consult PWT's Technical Bulletin 503 for further cleaning recommendations.

#### ProDose XPRT<sup>™</sup> – Scaling Prediction Software

ProDose XPRT<sup>™</sup> uses the most accurate scaling prediction calculations available to accurately determine effective antiscalant dosage, and cleaning chemical usage. The user can enter multiple cases to study various operating conditions, directly enter concentrate analysis, and select the best PWT product and dosage for the application.

ProDose XPRT<sup>™</sup> is available upon request only. Please contact your PWT representative for more information.

PWT Prodose			-		-			
	<b>N</b>							🤶 🤅
UNITS	TEMPERATURE	PERMEATE FLOW	RECOVERY	ANTISCALANT	DOSAGE	SOURCE	PROJECT NAME	CASE
US	Fahrenheit	81.00	75.0 %	SpectraGuard Liquid	2.95 PPM	Well Water	Project 1	1
		OVERVIEW				NTS		
PROJECT INFORMA	TION	CLIENT NAME:	City of San Diego		PRESET UNITS	CGS	Metric	U.S.
		PROJECT NAME:	Project 1		TEMPERATURE	E: Deg F		•
WATER QUALITY		LOCATION:			FLOW RATES:	Gal/min		•
		PREPARED BY:			MASS UNITS:	b		
		DATE:	5/1/2016	*	MASS UNITS:	10	_	
SYSTEM INFORMAT	ION	WATER TYPE:	Well Water	•				Enter
							Maz	
CHEMICAL SELECTION		COMMENTS (OPTIONAL)			Cases Modified Date			
	N I				1		5/27/2016	
CALCULAT	TONS							
					Selected Case	Description		
REPORT								
								_
		_	_			_	_	
				• • • •	•••			



### PWT Headquarters & Manufacturing 1048 La Mirada Court, Vista, California 92081

Toll-Free: 800.914.9072 | Direct: 760.639.4400 | Fax: 760.639.4439 Email: sales@pwtchemicals.com | www.pwtchemicals.com

Headquarters: 54/18 Bui Quang La, Ward 12, Go Vap District, HCMC, Viet Nam Office: 12 DHT10B, Dong Hung Thuan Ward, District 12, HCMC, Viet Nam Phone: (028) 6258 5368 - (028) 6291 9568 Email: info@atswatertechnology.com Website: www.atswatertechnology.com

WATER