

Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity



Zertifikat Nr. *Certificate No.*
J 50452200

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*
05-YFC-50263817 001

Ausstellungsdatum
20.01.2020

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

ADLER Elektrotechnik Leipzig
GmbH (i.G.)
Zschochersche Str. 91
04229 Leipzig
Germany

Fertigungsstätte *Manufacturing Plant*

ADLER Elektrotechnik Xi'an Co., Ltd.
Room 10205 of Modern enterprise center
A District No. 9 of Entrepreneurship
Research and Development Park, Jin Ye
Road No. 69, High tech zone
Xi'an city, Shanxi province 710077
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 60269-1:2007+A1+A2
EN 60269-6:2011

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

(Low-voltage Fuse for PV System)

Type Designation	: A94	5
Trademark	: ADLER (logo)	
Rated Voltage	: DC 1500V	
Rated Current (In)	: 10A, 12A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A, 45A, 50A, 55A, 60A, 65A, 70A, 80A	10
Rated Breaking Capacity	: 10kA	
Breaking range and Utilization category	: gPV	
Rated Power Dissipation	: no more than 10,5W at 0,7In no more than 15W at In	
Dimension	: 22mmx58mm (see appendix 1)	
Arc Voltage Limits	: 3800V (peak value)	
Remark: The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.		

15

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety



CERTIFICATE



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50458237 0001

Report No.: 50263817 001

Holder: ADLER Elektrotechnik Leipzig
GmbH (i.G.)
Zschochersche Str. 91
04229 Leipzig
Germany

Product: Fuse Link
(Low-voltage Fuse for PV System)

Identification: Type Designation: A94
Serial No. : Engineering Sample
Remark : Refer to J 50452200 0001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body



Date 20.01.2020

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

☞ The CE marking may be used if all relevant and effective EC Directives are complied with.

