

IZMR.E486822 - Fuseholders, Photovoltaic

Fuseholders, Photovoltaic

See General Information for Fuseholders, Photovoltaic

ADLER ELEKTROTECHNIK LEIPZIG GMBH

E486822

Zschochersche Str. 91
04229 Leipzig, GERMANY

Cat. No.	Voltage Rating	Current Rating	Interrupting Rating DC Amperes
BH10	1000/600	30	10,000
BH100	1000/600	30	10,000
BH100-00	1000/600	30	10,000
BH100-01	1000V dc	30 A	30,000
BH100-02	1000V dc	30 A	30,000
BH200 and BH201	1500 V dc	30 A	10,000
BH300 and BH301	1500 V dc	30 A	30,000
BH400 and BH401	1500 V dc	80 A	10,000
BH300-01 and BH300-02	1500 V dc	32 A	30,000

Trademark and/or Tradename: 

We use cookies to personalize content and ads, to provide

Last Updated on 2020-01-24

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-distorting manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"

analytics partners..

[Learn More](#)

[Cookie Settings](#)
 Accept