

# IZMR7.E486822 - FUSEHOLDERS, PHOTOVOLTAIC CERTIFIED FOR CANADA

## Fuseholders, Photovoltaic Certified for Canada

See General Information for Fuseholders, Photovoltaic Certified for Canada

**ADLER ELEKTROTECHNIK LEIPZIG GMBH**

E486822

Zschochersche Str. 91  
04229 Leipzig, GERMANY

Cat. No.	Voltage Rating	Current Rating	Interrupting Rating DC Amperes
<b>Photovoltaic fuseholder cartridge fuse</b>			
BH100	1000/600	30	10,000
BH100-00	1000/600	30	10,000
BH100-01	1000V dc	30 A	30,000
BH100-02	1000V dc	30 A	30,000
BH200 and BH201	1500 V dc	30 A	10,000
BH300 and BH301	1500 V dc	30 A	30,000
BH400 and BH401	1500 V dc	80 A	10,000
BH300-01 and BH300-02	1500 V dc	32 A	30,000

Last Updated on 2020-01-24

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions:  
1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"