

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50460275

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*
05-YFC-50250545 001

Ausstellungsdatum
18.03.2020

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Fertigungsstätte *Manufacturing Plant*

ADLER Elektrotechnik Leipzig
GmbH (i.G.)
Zschochersche Str. 91
04229 Leipzig
Germany

Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*
EN 60947-3:2009+A1+A2



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Fuse Holder (Fuse-disconnector)

Type Designation : BH400 BH401
Trade mark : adler (logo)
Utilization Category : DC-PV0
Number of Pole : 1 pole
Rated Operational Voltage (Ue) : DC 1500V
Rated Operational Current (Ie) : 80A
Rated Insulation Voltage (Ui) : 1500V
Rated Impulse Withstand Voltage (Uimp) : 12kV
Conventional Free Air Thermal Current (Ith) : 80A
Rated Conditional Short-circuit Current : 10kA
Pollution Degree : 3

6

Remark: The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA. The installation has to be carried out according to installation instruction accompanying the products.

6

ANLAGE (Appendix) : 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



CERTIFICATE



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50460732 0001

Report No.: 50250545 001

Holder: ADLER Elektrotechnik Leipzig
GmbH (i.G.)
Zschochersche Str. 91
04229 Leipzig
Germany

Product: Fuse Holder
(Fuse-disconnector)

Identification: Type Designation: BH400 BH401
Serial No. : Engineering Sample
Remark : Refer to R 50460275 0001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body



Date 18.03.2020

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with.

