

## ROUTINE TEST CERTIFICATE

### Reference Standards:

IEC 60947-1 \* IEC 60947-1-A1\* IEC 60947-3\* IEC 60947-5-1\* IEC 60947-5-1-A1  
EN 60947-1 \* EN 60947-1-A1\* EN 60947-3\* EN 60947-5-1\* EN 60947-5-1-A2  
VDE 0660-100 \* VDE 0660-107 \* VDE 0660-200

Order N° 20-CT-02/SC-CEL

Dated 11/02/2020

n°		Rotary Switch FR10	n°		Discrepancy Switch FRM10
n°		Rotary Switch R20	n°		Discrepancy Switch DR20
n°	179	Rotary Switch R16	n°	100	Discrepancy Switch DR16
n°		Rotary Switch R10	n°		Discrepancy Switch DR10
n°		Rotary Switch R8	n°		Discrepancy Switch DR8
n°		Rotary Switch FRMC 6	n°		Discrepancy Switch FRMM 6
n°		Rotary Switch FRMC 6 IP20	n°		Discrepancy Switch FRMM 6 IP20
n°		Rotary Switch FRMC 2000	n°		Discrepancy Switch FRMM 2000
n°		Auxiliary Switch FR10			
n°		Lock Out Relay LR20			
n°		CCDT R20			
n°		ICT R20			
n°		Soleinoid Lock Switch SR20			

### Routine Tests performed in accordance with the reference Standards

Visual Inspection

Verification of Mechanical Operation

Dielectric Verification

Series: FR10\*R20\*R16\*R10\*R8\*FRMC 6\*FRMC 6 IP20 \*LR20\*SR20

FRM10\*DR20\*DR16\*DR10\*DR8\*FRMM 6\*FRMM 6 IP20

**2500V ,2s**

FRMM 2000 \* FRMC 2000

**2000V ,2s**

TEST RESULT : **PASSED**

**WE CERTIFY THAT THE SWITCHES DESCRIBED ABOVE ARE MANUFACTURED AND TESTED IN ACCORDANCE WITH THE REFERENCE STANDARDS.**

Melegnano , Date 20/03/2020

The Inspector  
**COMELETRIC** S.r.l.

## ROUTINE TEST CERTIFICATE

**Reference Standards:**

IEC 60947-1 \* IEC 60947-1-A1\* IEC 60947-3\* IEC 60947-5-1\* IEC 60947-5-1-A1  
EN 60947-1 \* EN 60947-1-A1\* EN 60947-3\* EN 60947-5-1\* EN 60947-5-1-A2  
VDE 0660-100 \* VDE 0660-107 \* VDE 0660-200

Order N° 20-CT-02/SC-CEL

Dated 11/02/2020

n°		Rotary Switch FR10	n°		Discrepancy Switch FRM10
n°		Rotary Switch R20	n°		Discrepancy Switch DR20
n°	179	Rotary Switch R16	n°	100	Discrepancy Switch DR16
n°		Rotary Switch R10	n°		Discrepancy Switch DR10
n°		Rotary Switch R8	n°		Discrepancy Switch DR8
n°		Rotary Switch FRMC 6	n°		Discrepancy Switch FRMM 6
n°		Rotary Switch FRMC 6 IP20	n°		Discrepancy Switch FRMM 6 IP20
n°		Rotary Switch FRMC 2000	n°		Discrepancy Switch FRMM 2000
n°		Auxiliary Switch FR10			
n°		Lock Out Relay LR20			
n°		CCDT R20			
n°		ICT R20			
n°		Soleinoid Lock Switch SR20			

**Routine Tests performed in accordance with the reference Standards**

Visual Inspection

Verification of Mechanical Operation

Dielectric Verification

Series: FR10\*R20\*R16\*R10\*R8\*FRMC 6\*FRMC 6 IP20 \*LR20\*SR20

FRM10\*DR20\*DR16\*DR10\*DR8\*FRMM 6\*FRMM 6 IP20

FRMM 2000 \* FRMC 2000

**2500V ,2s**

**2000V ,2s**

TEST RESULT : **PASSED**

**WE CERTIFY THAT THE SWITCHES DESCRIBED ABOVE ARE MANUFACTURED AND TESTED IN ACCORDANCE WITH THE REFERENCE STANDARDS.**

Melegnano , Date 20/03/2020

The Inspector  
**COMELETRIC** S.r.l.

## ROUTINE TEST CERTIFICATE

### Reference Standards:

IEC 60947-1 \* IEC 60947-1-A1\* IEC 60947-3\* IEC 60947-5-1\* IEC 60947-5-1-A1  
 EN 60947-1 \* EN 60947-1-A1\* EN 60947-3\* EN 60947-5-1\* EN 60947-5-1-A2  
 VDE 0660-100 \* VDE 0660-107 \* VDE 0660-200

Order N° 20-CT-02/SC-CEL

Dated 11/02/2020

n°		Rotary Switch FR10
n°		Rotary Switch R20
n°	179	Rotary Switch R16
n°		Rotary Switch R10
n°		Rotary Switch R8
n°		Rotary Switch FRMC 6
n°		Rotary Switch FRMC 6 IP20
n°		Rotary Switch FRMC 2000
n°		Auxiliary Switch FR10
n°		Lock Out Relay LR20
n°		CCDT R20
n°		ICT R20
n°		Soleinoid Lock Switch SR20

n°		Discrepancy Switch FRM10
n°		Discrepancy Switch DR20
n°	100	Discrepancy Switch DR16
n°		Discrepancy Switch DR10
n°		Discrepancy Switch DR8
n°		Discrepancy Switch FRMM 6
n°		Discrepancy Switch FRMM 6 IP20
n°		Discrepancy Switch FRMM 2000

### Routine Tests performed in accordance with the reference Standards

Visual Inspection

Verification of Mechanical Operation

Dielectric Verification

Series: FR10\*R20\*R16\*R10\*R8\*FRMC 6\*FRMC 6 IP20 \*LR20\*SR20

FRM10\*DR20\*DR16\*DR10\*DR8\*FRMM 6\*FRMM 6 IP20

FRMM 2000 \* FRMC 2000

**2500V ,2s**
**2000V ,2s**

 TEST RESULT : **PASSED**

**WE CERTIFY THAT THE SWITCHES DESCRIBED ABOVE ARE MANUFACTURED AND TESTED IN ACCORDANCE WITH THE REFERENCE STANDARDS.**

Melegnano , Date 20/03/2020

 The Inspector  
